

Certificate

Passive House suitable component

For cool, temperate climates, valid until 31 December 2018

Category: **Heat recovery unit**
Manufacturer: **J. PICHLER Lufttechnik m.b.H**
9021 Klagenfurt, AUSTRIA
Product name: **LG 1400 System VENTECH**

This certificate was awarded based on the following criteria:

| | |
|------------------------------|---|
| Thermal comfort | $\Theta_{\text{supply air}} \geq 16.5 \text{ °C}$ at $\theta_{\text{outdoor air}} = -10 \text{ °C}$ |
| Effective heat recovery rate | $\eta_{\text{HR,eff}} \geq 75\%$ |
| Electric power consumption | $P_{\text{el}} \leq 0.45 \text{ Wh/m}^3$ |
| Performance number | ≥ 10 |
| Airtightness | Interior and exterior air leakage rates less than 3% of nominal air flow rate |
| Balancing and adjustability | Air flow balancing possible: yes Automated air flow balancing: yes |
| Sound insulation | It is assumed that large ventilation units are installed in a separate building services room. Sound levels documented in the appendix of this certificate |
| Indoor air quality | Outdoor air filter F7 Extract air filter G4 |
| Frostprotection | Frost protection required. Recommendations given in the appendix |

- 1) Available pressure difference with integrated filters for application in non residential buildings: **185 Pa**.
- 2) Available pressure difference with device integrated filters for application in residential buildings: **148 Pa**.

Additional components (e.g. heater coil) decrease the available pressure difference accordingly.

Further information can be found in the appendix.

www.passivehouse.com

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
GERMANY



Certified for range of application:

350 – 1100 m³/h

At an external pressure of **228 Pa¹⁾**
(non residential)

350 – 1200 m³/h

At an external pressure of **198 Pa²⁾**
(residential)

$\eta_{\text{HR,eff}}$ **83%**
(non residential)

$\eta_{\text{HR,eff}}$ **82%**
(residential)

Electric power consumption

0.39 Wh/m³

(non residential)

0.38 Wh/m³

(residential)

Performance number

10.8 (non residential)

11.3 (residential)



*Passive House
suitable
component*
Dr. Wolfgang Feist

Appendix of certificate J. PICHLER Lufttechnik m.b.HLG 1400 System VENTECH

Manufacturer J. PICHLER Lufttechnik m.b.H
Karlweg 5, 9021 Klagenfurt, AUSTRIA
Tel: +43 463 / 32769
E-Mail / Website: office@pichlerluft.at, www.pichlerluft.at

Passive House comfort criterion

A minimum supply air temperature of 16.5 °C is maintained at an external air temperature of -10 °C.

Effective heat recovery rate

The effective dry heat recovery efficiency is measured at the test facility using balanced mass flows on the external air/extract air side. The boundary conditions for the measurement should be taken from the documents relating to the testing procedure.

$$\eta_{HR,eff} = \frac{(\vartheta_{ETA} - \vartheta_{EHA}) + \frac{P_{el}}{m \cdot c_p}}{(\vartheta_{ETA} - \vartheta_{ODA})}$$

The (dry) ventilation heating load (the house is the system boundary) can be calculated using $\eta_{HR,eff}$ based on the formula $V_{supply\ air} \cdot (1 - \eta_{HR,eff}) \cdot 0.34 \cdot \Delta\vartheta$ (multiplied by the infiltration rate). The rates of heat recovery are usually greater if condensation occurs in the heat exchanger. Initially, this will not be taken into account on purpose.

In this case:

$\eta_{HR,eff} = 83\%$ (non-residential)

$\eta_{HR,eff} = 82\%$ (residential)

Air flow range and external pressure difference

The air flow range of this device is limited by the required maximum electric power consumption. Referred to the PHI-criteria for ventilation units > 600 m³/h different external pressure differences according to the upper limit of the air flow range and the application (residential building or non-residential building) are required.

Thereby the external pressure difference is defined by all pressure losses in the ventilation system (whole ducting system) outside of the tested unit, which only consists of casing, heat exchanger and fans. If filters are already installed in the appliance, the external pressure difference can be reduced by the average filter pressure drop. (it is assumed that the average filter pressure drop in operation is 30% higher than the filter pressure drop of the clean filter).

- According to the requirement of non-residential buildings with an air flow range of 350 - 1100 m³/h at an external pressure difference of 228 Pa. The available pressure difference with installed filters is about **196 Pa**
- According to the requirement of residential buildings with an air flow range of 350 - 1200 m³/h at an external pressure difference of 198 Pa. The available pressure difference with installed filters is about **162 Pa**

Efficiency criterion (power consumption)

The overall electrical power consumption of the device including the regulation, excluding the frost protection heating, is tested at the test facility for the requirements of non-residential and residential buildings at an external pressure difference of 228 / 198 Pa.

Measurement results: **0.39 Wh/m³** (non-residential / residential)

Appendix of certificate J. PICHLER Lufttechnik m.b.HLG 1400 System VENTECH

Based on the measured values for the calculation of heat recovery efficiency and power consumption and on the climatic data of middle Europe (Gt: 84 kWh, heating time: 5400 h/a), an average performance number at the air flow range was determined:

- ✓ **Performance number: 10.8 / 11.3** (non-residential / residential)

Airtightness and insulation

Before starting the thermodynamic test, the air tightness test should be carried out for under pressure as well as for over pressure (according to the measurement requirements). The leakage air flows must not be greater than 3 % of the average air flow volume of the operating range of the ventilation device.

The following result was obtained for the device being tested:

Internal leakage: 0.56 / 0.52 % (non-residential / residential)

External leakage: 0.39 / 0.36 % (non-residential / residential)

This appliance meets the air tightness requirements.

Balancing and adjustability

All units must have a possibility to adjust the balance between the exhaust air flow rate and the outdoor air flow rate.

- Balancing the air flow rates of the unit:
 - ✓ Automated air flow balancing (by measurement of pressure differences at the fan's injections)
 - ✓ The installation situation of the fans within the unit is considered. The volume flow control is adjusted to the measured differential pressure. The volume flow control was measured. In the medium range of operation the deviation of the volume flows measured was smaller than 3%.
- This ventilation appliance has a very low standby consumption of 2.8 W.
- After a power failure the device automatically continues to operate in the mode that was set before the power failure.

Acoustical testing

For ventilation units > 600 m³/h an installation in a separate room for building services could be assumed, which is planned according to the valid regulation. Following sound levels have been determined at an air flow rate of **1100 / 1200 m³/h**:

| Sound level unit [dB(A)] | Sound level ODA [dB(A)] | Sound level SUP [dB(A)] | Sound level ETA [dB(A)] | Sound level EHA [dB(A)] |
|-----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| 60.5 / 60.1 | 60.2 / 61.4 | 71.5 / 70.9 | 62.3 / 60.4 | 72.0 / 73.1 |

- For complying with the required sound level in the supply air and extract air rooms, dimensioning of suitable silencer is required for the specific project on the basis of the measured sound level.

Appendix of certificate J. PICHLER Lufttechnik m.b.H, LG 1400 System VENTECH

Indoor air quality

Inspection and cleaning of the central device including the heat exchanger is simple. The filter can be replaced by the user himself/herself (no specialist required), relevant information should be provided and suppliers of filters should be listed in the manual. At least the following filter types should be provided for protection from pollutants:

- ✓ Outdoor Air filter at least F7
- ✓ Extract Air filter F5

If the device is not operated during the summer, the filter should be replaced before the next operation. The manufacturer is responsible for ensuring indoor air hygiene based on the latest findings, either by means of device components or by providing the obligatory equipment with the device.

For the operation of ventilation systems a strategy for avoiding permanent moisture penetration of the outdoor air filter need to be considered. The strategies are mentioned in the full report and can be implemented through installations of either additional components of the ventilation device or on the ventilation site system.

Frost protection

Appropriate measures should be taken to ensure prevention of icing over of the heat exchanger and freezing up of hydraulic post-heater coils during extreme winter temperatures (-15°C). The regular functioning of the device should be permanently ensured during uninterrupted operation of the frost protection circuit (there is no interrupt circuit for outdoor air in the Passive House, as the heating loads caused by the forced infiltration would become too high). If heater coils for hot water are used, a suitable frost protection circuit should ensure prevention of frost damage to these heater coils. In the process, the possibility of failure of the pre-heating coils and extract air fans must also be taken into consideration.

- Frost protection circuit for the heat exchanger:

As per manufacturer information several frost protection systems can be applied: preheating through a brine ground heat exchanger, bypassing the heat exchanger and post-heating of the supply air with a hydraulic heater coil, utilization of an electric pre-heater (comes optionally with the unit). All strategies are described in the test report.

- Frost protection circuit for downstream hydraulic heater coils:

Also the hydraulic post-heating coil requires frost protection. If it is operated without antifreeze fluid a thermostat needs to be installed at the ventilation unit's supply air outlet. This signals any risk of frost to the device. At an activation of the thermostat the control of the ventilation device shuts off the fans, it opens the mixing valve of the heater coil shuts off the circulation pump.

It should be noted that cold air can also lead to freezing up if the fans stand still due to free circulation. This can be avoided by closing the air duct with shut-off flaps.

Bypass of the heat recovery

A summer bypass of the heat recovery is part of this appliance. It is applicable for night ventilation strategies in order to dissipates heat. The fans cause a temperature raise of 2K (at ODA 16°C / EHA 24°C). The effectiveness of the bypass for night cooling has been tested.

Abbreviations: ODA = Outdoor air, EHA = Exhaust air, SUP = Supply air, ETA = Extract air